Website: www.nitandhra.ac.in
Email: purchase@nitandhra.ac.in



राष्ट्रीय प्रौद्योगिकी संस्थान आंध्रप्रदेश
**NATIONAL INSTITUTE OF TECHNOLOGY ANDHRA PRADESH**
Near National Highway No. 216A, Kadakatla, Tadepalligudem – 534101
West Godavari District, Andhra Pradesh



**Ref. No.**: NITANP/SMMD/TENDER/2026-27/ 11

**Date**: 18.06.2026

# TENDER ENQUIRY

**Sub**: **Supply of "Electrical Materials for Additional Floor Ports in T&P Cell, Dr. B. R Ambedkar Central Library"at NIT Andhra Pradesh - Quotation invited –Reg.**

---

Please send your lowest quotation for the above work/supply as per the specifications/ requirements mentioned in **Annexure-1**. The lowest quotation must be submitted ON FIRM LETTER HEAD in the given format **(Annexure-1 along with necessary documents as specified and duly abiding to the important instructions**), failing which bid shall be treated as Unresponsive. The quotation is to be sent in a sealed envelope to the following address:

**C/o Tender Box**
**Material Management & Disposal Section (006, Ground Floor)**
**Sardar Vallabhbhai Patel Administrative Building**
**National Institute of Technology Andhra Pradesh,**
**Near National Highway No. 216A, Kadakatla,**
**Tadepalligudem – 534101**
**West Godavari District, Andhra Pradesh.**

**The quotation has to be sent by Post (Ordinary / Register / Speed Post) or drop in Tender Box physically. (Any other mode will not be accepted)**

The envelope must be superscribed as "**QUOTATION**" at the center of the envelope and the above **reference number at left top** along with the **Subject of the tender** on the envelope.

Please note that the bid envelope received without the above-mentioned superscription **shall be treated as UNRESPONSIVE**.

The last date to receive the sealed envelope with quotation is **09.07.2026.**

## Annexure-1

**Name of the Work: Supply of "Electrical Materials for Additional Floor Ports in T&P Cell, Dr. B. R Ambedkar Central Library" at NITANP.**

| S. No | Description of items | Make | Qty | Units | Unit Price | Amount (Rs.) |
|---|---|---|---|---|---|---|
| 1 | 3/4" UPVC Pipes | Prince/Sudhakar/Astral | 25 | No's | | |
| 2 | 3/4" UPVC L short Bends | Prince/Sudhakar/Astral | 13 | No's | | |
| 3 | 3/4" UPVC T Bends | Prince/Sudhakar/Astral | 05 | No's | | |
| 4 | 3/4" UPVC SS Clamps | Prince/Sudhakar/Astral | 100 | No's | | |
| 5 | 3/4" PVC Electrical Pipes | - | 20 | No's | | |
| 6 | 3/4" PVC L Short Bends | - | 20 | No's | | |
| 7 | 2.5 Sqmm Wire (Red-2coils, Black-2 coils) | Polycab/RR/Havells/ Finolex | 04 | Coils | | |
| 8 | 1.5 Sqmm Wire (Green) | Polycab/RR/Havells/ Finolex | 03 | Coils | | |
| 9 | 4 Modular Flanks | Legrand MyLink | 20 | No's | | |
| 10 | 8 Modular PVC Surface Box | Goldmedal /Havells/Legrand | 32 | No's | | |
| 11 | 16A 2 in 1 Sockets | Legrand MyLink | 128 | No's | | |
| 12 | 5 No Fischer | Fischer | 02 | Boxes | | |
| 13 | 5 No Drill Bit | | 03 | No's | | |
| 14 | MCB PVC Gang Box 2 Pole | - | 10 | No's | | |
| 15 | 25mm Wood Core Bit | | 02 | No's | | |
| 16 | 20 A Switch Type MCB | Legrand Arteor | 02 | No's | | |
| 17 | Spring Box | - | 01 | Box | | |
| | | | | **Sub Total** | | |
| | | | | **GST@____%** | | |
| | | | | **Grand Total** | | |

**The Firm/Bidder must submit following documents along with Quotation failing which bid shall be treated as UNRESPONSIVE:**

1. Certificate of GST Registration.
2. Copy of the tender document and enclosures with Bidder's signature and seal.

**Important Instructions:**

1. L1 will be identified based on the consolidated quoted price if otherwise not specified in the bid document.
2. The quotation should not contain any handwritten text except the Price quoted.
3. Rates should be clearly quoted against each item.
4. The quotation shall be valid for a minimum period of 90 Days from the closing date of the Bid.
5. The price quoted should be F.O.R. Destination (including Freight, insurance, loading, unloading at specific location in the premises of NIT Andhra Pradesh).
6. The Bidder shall inscribe the Tender reference number and Tender Subject on the bid envelope submitted to the Institute.
7. Please note that the Director reserves the right to modify or alter the specifications and also to reject any or all the Quotations without assigning any reasons thereto.
8. The Institute is not responsible for delays / loss in postal transit or due to any other reasons in regard to timely receipt of the bid.

**Sd/-**
**Associate Dean, P&D (SMMD)**